



July 29, 2014

A-DEC INC.
REGULATORY SERVICES
ROBERT NAPORA
2601 CRESTVIEW DRIVE
PO BOX 111
NEWBERG OR 97132

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: A-DEC INC.
Product Name: DENTAL DELIVERY SYSTEMS
Model Number(s): PREFERENCE II TREATMENT CONSOLES 5551, 5552 AND 5557
Product File No: 20140236

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2019.

This approval supersedes the approval issued on August 17, 2009 under product file number 20090288.

This approval is contingent upon compliance with the following stipulation(s):

- The potable water piping serving these devices (i.e. hot, cold and high purity) shall be isolated from the building's water supply system by installing a reduced pressure principle backflow preventer (i.e. RPZ). The RPZ shall conform to ASSE Standard 1013.
- The RPZ's shall be installed in accordance with s. SPS 382.41 (5) Wis. Adm. Code.
- The RPZ's shall be registered, maintained and repaired in accordance with s. SPS 382.22 Wis. Adm. Code.
- The wastewater from these devices shall be conveyed to the drain, waste and vent (i.e. DWV) system via an air gap. The air gap shall conform to ASME A112.1.2.
- The DWV piping down stream of these devices shall be properly sized to handle the additional wastewater flow and of a material suitable for the maximum wastewater temperature generated by these devices.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail